Approved For Release 1999/08/24 : CIA-RDP78-04782A000100050019-6

b. Safety Requirements

(1) A combination, automatically resettable, rate-of-rise and set temperature fire detection system to annunciate at the main guard control center.

2. Should any question arise concerning this memorandum, please contact the Chief, Survey Branch, Physical Security Division, extension 6091.

25X1A9a [redacted]

Chief, Physical Security Division, OS

Approved For Release 1999/08/24 : CIA-RDP78-04782A000100050019-6

GROUP 1
Excluded from automatic downgrading and declassification